


Test Verification of Conformity

Verification Number: 251009019GZU-VOC001

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Fortress Power LLC 2010 Cabot Blvd W Suit L, Langhorne PA 19047, US
Product Description:	Grid Support Hybrid inverter
Ratings & Principal Characteristics:	Max input voltage (dc):550V Battery voltage operating range (dc):40-60V Nominal AC voltage:208Vac/240Vac Nominal AC frequency:60Hz
Models/Type References:	FP-Envy-Duo 21, FP-Envy-13K
Brand Names:	Fortress Power
Specification<s>/Standards:	Outline of Investigation for Power Control Systems [UL 3141 Issue Number: 1 January 11, 2024] Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3] CRD for Power Control Systems (PCS) issued on March 8, 2019
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch. Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China
Date of Tests:	06 Jul. 2025 - 20 Jul. 2025
Test Report Number(s):	251009019GZU-001, 11 Oct. 2025



Signature

Name: Jason Fu

Position: Manager

Date: 11 October 2025

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.